

From: Robert S. Trahan [rtrahan@geoengineers.com]
Sent: Monday, June 24, 2013 7:11 PM
To: Liverman, Earl
Cc: Terry Cundy (Terry.Cundy@potlatchcorp.com); John M. Herzog; Abhi R. Joshi; Nathan Solomon; Robert S. Trahan
Subject: Avery Landing Removal Action - Water Treatment System Startup Sample Results
Attachments: Water Treatment System Sample Summary Table.pdf

Earl,

For your consideration, analytical results for the startup testing phase of the water treatment system are summarized in the attached table and include both influent (untreated) and effluent (treated) results. In accordance with the EPA-approved Work Plan, transition from the startup testing phase to the operational testing phase will be initiated following the demonstration that five consecutive 10,000 gallon batches, totaling 50,000 gallons of treated water meet the discharge requirements for the removal action. Effluent sample results for batches 8 through 15, totaling 80,000 gallons of treated water meet the requirements off the initial startup testing phase. With your approval, water treatment system testing will transition to the operational testing phase. Additionally, treated water will be discharged to the St. Joe River and/or reused for dust control for the removal action. Please don't hesitate to call with any question.

Thank you,

Robert S. Trahan
Geologist | GeoEngineers, Inc.
Telephone: 206.239.3253
Fax: 206.728.2732
Mobile: 206.240.2300
Email: rtrahan@geoengineers.com

600 Stewart Street, Suite 1700
Seattle, WA 98101
www.geoengineers.com

Disclaimer: Any electronic form, facsimile or hard copy of the original document (email, text, table, and/or figure), if provided, and any attachments are only a copy of the original document. The original document is stored by GeoEngineers, Inc. and will serve as the official document of record.

Confidentiality: This message is confidential and intended solely for use of the individual or entity to whom it is addressed. If you are not the person for whom this message is intended, please delete it and notify me immediately, and please do not copy or send this message to anyone else.